## NA+ION ENERGIE

Sodium-ion Batteries Pty Ltd (ACN 648 388 747) trading as Nation Energie Level 2, 1 Collins Street Melbourne Australia 3000 P +61 3 9661 8911 nationenergie.com

#### **Pack Specifications.**

Model Name	Faradion WESTNAB	
Electrical Specification		
Nominal Energy	11.5 kWh	
Usable Energy	9.5 kWh	
Nominal DC (battery) Input voltage	48VDC	
DC (battery) voltage range	43-53VDC	
Max. DC (battery) current	60A	
Continuous Charge/Discharge	C/3	
Overcharge Protection	Yes	
Cell roundtrip efficiency	~95% @ C/5	
Demo unit roundtrip efficiency	~90% @ C/5	
Communication protocol	CANBus	

Mechanical/Environmental Specification		
Dimensions (W x L x H)	58 cm x 31.5 cm x 132 cm	
Weight	190 kg	
IP Rating	IP20	
Installation	Floor standing	
Cooling method	Natural Cooling + Fan Assisted Ventilation	

## NA+ION ENERGIE

Sodium-ion Batteries Pty Ltd (ACN 648 388 747) trading as Nation Energie Level 2, 1 Collins Street Melbourne Australia 3000 P +61 3 9661 8911 nationenergie.com

Operating Temperature Range	-20°C to 45°C	
Recommended Ambient Temperature range	0°C to +30°C	
BMS Cutoff Temperature	55°C	
Storage Temperature Range	-20°C to + 45°C	
Humidity Range	0-85% RH, Non-condensing	

Demonstrated compliance with	
IEC 61000-4	
EN 61000-3-2:2015-03	
EN 61000-6-1:2007	
EN 61000-6-3:2007 + A1:2011	
IEC 62619:2017	
UN38.3	

# NA+ION ENERGIE

Sodium-ion Batteries Pty Ltd (ACN 648 388 747) trading as Nation Energie Level 2, 1 Collins Street Melbourne Australia 3000 P +61 3 9661 8911 nationenergie.com

#### Pack Warranty / cycle life.

The Product will have an initial usable energy capacity of 9.5 kWh and will retain usable energy capacity as shown in the table below:

Application	Energy Retention (column 1)	Operating Limitation (column 2)
Solar self-consumption/ backup only to which both columns 1 and 2 apply	Minimum 70% of the initial usable energy capacity up to 10 years following the Installation	No limit on cycles within the 10 years following Installation
Any other application or combination of applications, the first to occur of columns 1 and 2, after which the other column will no longer be warranted	Minimum 70% of the initial usable energy capacity up to 10 years following the Installation	21.0 MWh of aggregate throughput (measured at DC-battery output)