

#### **HAZARDOUS LOCATION CERTIFIED - HAZLOC- C1D2**



#### ABOUT US

Hub Solar's commitment to engineering excellence are evident in our ruggedized C1D2 family of solar panels. Meeting today's most stringent hazardous location standards, and using the best available materials and technologies.

Our manufacturing facilities are world class and operate in strict accordance to ISO 9001 standards.

Our process controls, quality control and flash testing, ensure manufacturing excellence.

## **Applications**



Offgrid Industrial Sites



Communications Sites



Oil & Gas Sites




Mountain Top



EEE Commercial on Grid



Offshore Sites



HSM36-200-G1





#### DETAILS

## Start at the core


- Industrial Grade Design
- Robust Aluminum Frame
- 3.2mm Glass Cover
- Thick Backing Cover
- **Factory Installed Leads**
- Mono Crystalline Cells
- **ISO Standards**


114 - 4238 Lozells Ave Burnaby, BC, V5A 0C4 E-mail: sales@hubpower.ca | www.hubpower.ca

Phone: 604-420-7737

#### MONO CRYSTALLINE SOLAR MODULE

# HSM36-200-G1





Anodized Aluminium

STC: Irradiance 1000 W/m<sup>2</sup>; SpectrumAM1.5; Cell Temperature 25°C, Wind 0 m/s

Туре	HSM36-200-G1	
Type of Solar Cell	Mono-crystalline, 158.75mm×158.75mm	
Number of Cells	36	
Size of module	1500×680×35mm (158.75x158.75mm cell)	
Module, Weight	10.7kg	
Connector	Low Profile Junction Box with Wire Leads	
Cables	Customizable	
Front Cover Glass	Safety Glass	
Front Cover Glass, Thickness	3.2 mm	



### **ELECTRICAL DATA**

Maximum Power	200W
Power Tolerance	+ 3%
Maximum Power Voltage - Vmpp	20.15V
Maximum Power Current - Impp	9.92A
Open Circuit Voltage - Voc	24.55V
Short Circuit Current - Isc	10.50A
Cell Efficiency	22.3%
Maximum System Voltage	1000V

#### **TEMPERATURE COEFFICIENTS**

Power Coefficient	-0.50 ±0.05%/K
Voltage Coefficient	-0.35 ±0.01%/K
Current Coefficient	0.065 ±0.015%/K

#### **SAFETY STANDARDS & CERTIFICATIONS**

Frame

- Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Standard(s): Hazardous (Classified) Locations [UL 121201:2017 Ed.9+R:APRIL 1, 2021]
- Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations [CSA C22.2#213:2017 Ed.3+U1;U2;U3]

IEC 61215, IEC 61730 ,TUV, CE, ISO9001:200











WARRANTY